



City of Sandy Springs Fire Department

Community Risk Reduction

Fire Watch Requirements

A fire watch is a temporary measure taken when deemed necessary by the Fire Marshal. A fire watch may be required in the event that an automatic fire protection system is impaired or is out of service, when overcrowding is expected; the nature of the activities warrants it, or other necessary reasons. This service is intended to ensure continuous and systematic surveillance of a building or its protected portion(s) by one or more qualified individuals who are responsible for identifying and controlling fire hazards, maintaining means of egress, detecting early signs of fire, raising an alarm of fire, and notifying the fire department

Owner/Management Responsibilities

The owner/manager is responsible for providing the required personnel, equipment, or fire protection from hazards and to ensure the necessary protection is made ready and reliable.

Fire Watch Duties and Responsibilities

- The primary function of a fire watch is to detect fire, notify occupants and the fire department, and evacuate the protected area or building. Firefighting activities are **NOT** the primary purpose of the fire watch
- Fire watch personnel are to remain on the property to assist the fire department with information and establishing contact with the owner/manager

The duties of the fire watch are:

- Conduct periodic patrols of the protected area(s) or the entire facility, as appropriate
- Identify any life safety, fire, or property hazards
- Prevent obstruction of means of egress. Notify the fire department when a fire is suspected or discovered



City of Sandy Springs Fire Department

Community Risk Reduction

- Call 911 and provide the emergency operator with the exact address, type of emergency, and if applicable, advise that the fire protection system is impaired
- Notify building occupants of the need to evacuate; if a building alarm system is functional, ensure it is activated to assist with the evacuation
- Establish and maintain at least one means of direct communication with the 911 Emergency Communication Center
- Maintain a log of the fire watch tours and activities
- Be knowledgeable in the location and use of fire protection equipment, including portable fire extinguishers
- Fire watch personnel have the sole duty of providing a fire watch; other duties may be assigned by the Fire Marshal, as appropriate

Notify Occupants of the building

The attached notice shall be placed at all entrances to the building on fire watch in addition to notifying the occupants.

Frequency of Tours, Continuous Intervals

Fire watch personnel should patrol the entire area continuously when the following conditions exist:

1. Where the occupants are sleeping
2. Where occupants are incapable of self-preservation or require assistance
3. In occupancies where high numbers or concentrations of people are expected (i.e., places of assembly and educational occupancies)

60 (Sixty) Minute Intervals

All other occupancies not meeting the requirements for continuous intervals will be patrolled by the fire watch in 60 minute intervals.



City of Sandy Springs Fire Department

Community Risk Reduction

Recordkeeping

A fire watch log shall be maintained at the protected facility and available to the fire department at all times during the fire watch.

The fire watch log should contain the following information:

- Address of the facility/protected area
- Name of person(s) on-duty conducting the fire watch
- Date and time of fire watch duty
- Beginning and ending times of each patrol
- Name of fire watch member conducting a specific patrol
- Record of communication(s) with the fire department and alarm monitoring company; including time(s) and nature of communication
- Record of other information, as directed by fire department personnel

Conclusion of Fire Watch Operations

The owner/manager is responsible for requesting conclusion of the fire watch once the fire protection system has been restored and functional or the hazardous conditions no longer exists. Once the fire watch has been approved for discontinuance by the Fire Marshal, the owner or their representative must notify the alarm monitoring company if applicable.